



**Bureau of Fire Prevention
Office of the Fire Marshal**

Runnemede Municipal Building
24 N. Black Horse Pike
Runnemede, NJ 08078
856-939-2817
Fax: 856-939-0981

**Michael Kearney
Captain / Fire Official**

NJ UNIFORM FIRE CODE: COOKING VENDOR GUIDELINES

- The following are minimum guidelines for each cooking vendor at festivals, carnivals, etc.
- A site plan may be required by the Fire Official prior to event.

FIRE SAFETY PERMIT: Cooking vendor permits – a permit application shall be submitted through the Runnemede Bureau of Fire Prevention for each vendor for every event.

N.J.A.C. 5:70-2.7(a); All cooking vendors shall be required to apply for a fire safety permit through the Runnemede Bureau of Fire Prevention. All permits shall be made available to the Fire Official upon inspection.

N.J.A.C. 5:70-2.9(c)1; Type 1 \$54.00 Permit Fee is required. **NO CASH** will be accepted. Vendor shall provide a check or money order payable to “Borough of Runnemede”. Permits will not be issued unless payment is made in full. This is an application processing fee and is not refundable.

N.J.A.C. 5:70-2.7(f); The fire official upon inspection may deny or revoke a permit at any time; this can be due to failure to meet the permit conditions, unabated fire code violations or unsafe conditions.

FIRE EXTINGUISHER: All cooking vendors shall supply their own fire extinguishers.

N.J.A.C. 5:70-3, 906.2; All fire extinguishers shall comply with NFPA 10. All fire extinguishers shall have a valid dated inspection tag, good of one year.

N.J.A.C. 5:70-3, 904.12.5; Class K portable fire extinguishers are required for cooking with vegetable or animal oils and fats.

N.J.A.C. 5:70-3, 904.12.5.1; Class K portable fire extinguishers are required for cooking with solid fuel.

N.J.A.C. 5:70-3, 904.12.5.2; Class K portable fire extinguishers required for deep fat fryers. (See 2015 IFC-NJ for size and quantity)

LIQUIFIED PETROLEUM GASES (Propane Tanks):

N.J.A.C. 5:70-3, 5303.5.3; Propane tanks shall be secured, to prevent falling over.

N.J.A.C. 5:70-3, 6104.1; Propane tanks and equipment shall comply with NFPA 58.

MOBILE CANTEENS & COOKING TRAILERS:

N.J.A.C. 5:70-4.7(g) All cooking operations that produce grease laden vapors shall be equipped with a ventilating hood, duct, and automatic fire suppression system.

N.J.A.C. 5:70-3, 906.4; Fire extinguishers provided for the protection of cooking grease fires shall be of an *approved* type compatible with the automatic fire-extinguishing system agent and in accordance with Section 904.12.5.

N.J.A.C. 5:70-3, 904.5; Wet chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17A.

N.J.A.C. 5:70-3, 904.6; Dry chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17.

N.J.A.C. 5:70-3, 609.3.3; Excessive grease and residue buildup on kitchen exhaust systems, cleaning required.

MISCELLANEOUS:

N.J.A.C. 5:70-3, 104.3; All appliances shall be listed and labeled and approved by the fire code official. (No homemade appliances).

N.J.A.C. 5:70-3, 3104.7; Cooking devices shall not be permitted inside or located within 20 feet of a tent or membrane structure unless *approved* by the *Fire Official*.

N.J.A.C. 5:70-3, 3104.15; Cooking equipment within tents shall be in accordance with Sections 3104.15.1 – 3104.15.7. (See 2015 IFC-NJ Chapter 31, Tents and Other Membrane Structures). *Additional permits, including ICC permits may be required.*

- Liquefied Petroleum Gas cylinders between 4 and 40 lbs shall have an Overfill Protection Device for filling in NJ.
- Liquefied Petroleum Gas cylinders shall be hydro tested every 12 years or per manufacture requirements, and not dented or badly rusted.
- Regulator shall be in good condition and the relief valve shall face away from the public areas.
- All plastic type protective caps shall be removed from all propane tanks before operating.
- Hoses shall not be frayed or cracked, and there shall not be any type of tape on the hose.
- Hoses shall not be covered with grease and shall not be swollen.
- Hoses shall not create a tripping hazard
- Only approved lighter fluid shall be used for charcoal grills.
- Chafing dish gel fuel warmers may be used provided the fuel containers are properly protected from being knocked over and if the fuel containers are properly enclosed within the warmer units.